

CA120

Ref: Ca120-0

Revision: 00

Author:

Cable code	CA120
Description	UniOP PLC Port to K-M Suconet K
Type of Communication	RS-485
Panel Connector	D-sub type 15S
PLC Connector	Circular DIN 5 pin
Notes	Must be used with panels with extension -0043 (TCA05 module) and 15 pin connector. This cable replaces CA105 which has a 9 pin connector on panel side.

table 1. Cable description




figure 1. Cable diagram




figure 2. Connector front view (pin side)