


Important !
 Disconnect power to the main board before making any changes to DIP switches/Jumpers and while wiring the unit .

Protocol	SW1.1
MODBUS	On
BACNET	Off

Baud rate	SW1.4	SW1.5	SW1.6
4,800	On	On	On
9,600	Off	On	On
19,200	On	Off	On
28,800	Off	Off	On
38,400	On	On	Off
57,600	Off	On	Off
86,400	On	Off	Off
115,200	Off	Off	Off

(Default)

SW1.2 , SW1.3 - Not in use.



meitav-tec

Tel: +972-3-9626462
 Fax: +972-3-9626620
 e-mail: support@meitavtec.com

Title:

CTU2646

Date: 29.06.11

Rev.1

Original

29.06.11

Print name: I-O-CARD_B

Software: 11402801.BIN

Checksum: 02FEE8EE

File: CTU2646.vsd

Drawn: P.Rechtman

Checked: A.Star

Approved: A.Samocho