



**Occupancy Sensor**  
When the DI8 input (N.C) is open for 10 minutes, all outputs turn Off.

- Digital Inputs**
- DI1,0** - Unshort always
  - DI2,0** - **Fault 3** input (N.C.)  
Only for indication through the protocol
  - DI3,0** - **Fault 4** input (N.C.)  
Only for indication through the protocol
  - DI4,0** - **Fault 5** input (N.C.)  
Only for indication through the protocol
  - DI5,0** - **Fault 1** input (N.C.)  
When open – all outputs OFF (no delay)
  - DI6,0** - **FAN** – Short – Fan Only mode available (Selectable through thermostat)  
Open – Fan Only mode not available
  - DI7,0** - **Fault 2** input (N.C.)  
Only for indication through the protocol

- DIP switch Configuration (S2)**
- S2.1** – Fan ON / Auto fan configuration in cool/heat
    - ON - Auto fan (always)
    - OFF - Fan ON (always)
  - S2.2** – 2-pipe / 4-pipe system
    - ON - 4-pipe
    - OFF - 2-pipe
  - S2.3** – OFF - Not in use
  - S2.4** – “End of network” configuration
    - ON - End of network
    - OFF - Not end of network
- Default:

**Open/close time of the valves**  
150 seconds by default. Adjustable through protocol (0...500 sec.)

- Temperature Sensors Logic**
- T1,0 - Return air sensor**  
The ambient (room) temperature can be sensed via the return air sensor.
  - T2,0 - Change-over sensor**  
Mode is automatically selected, based on the water temperature sensed by T2 (2-pipe system only) T2 > 30°C → Heat, T2 < 20°C → Cool
  - T3,0 - Indoor coil sensor**  
**Soft-start in Heat**  
When T3 rises above (or equals) 36°C → The indoor fan will start working (according to FAN ON or AUTO FAN state)  
When the temperature drops below 32°C → The indoor fan will turn OFF.  
  
\*When T3 is not connected:  
- If AUTO FAN is selected, the indoor fan will start working 30 seconds after demand for heat.  
- If FAN ON is selected, the indoor fan will work continuously.

<b>meitav-tec</b> Tel: +972-3-9626462 Fax: +972-3-9626620 e-mail: support@meitavtec.com	Title: <b>CTU4500-PM2-3S-FC-SUPER</b>			Print name: PS-2600	Drawn: M.Ruchansky
	Date: <b>27/11/2007</b>		1	Original	27.11.07
			No.	Revision	Date
				Software name: 50101001	Checked: O.Volovitch
				Check sum : AF2D	Approved: E.Roy